



This certificate is not valid if the serial number has been defaced or altered

ESN2/ 0013790

# EMERGENCY LIGHTING COMPLETION CERTIFICATE

For small installations and verification of existing installations

Issued in accordance with BS 5266-1, by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZX.

Original (To the person ordering the work)

<b>A DETAILS OF THE CLIENT</b>		<b>C PURPOSE OF CERTIFICATE</b>	
Client/Address	Blenheim Realty (Home Counties)	Postcode	CM21 9FB
<b>B DETAILS OF THE EMERGENCY LIGHTING INSTALLATION</b>		Verification of existing installation or Small installation work <input type="checkbox"/> The installed work is: New <input checked="" type="checkbox"/> An addition <input type="checkbox"/> An alteration <input type="checkbox"/>	
Address	28 Ferndale Road	Postcode	ME7 2PD
Extent of the installation covered by this certificate	4 Bed House / HMO.		
<b>D DETAILS OF THE ORGANISATION RESPONSIBLE FOR CERTIFICATION/VERIFICATION*</b> (*delete as appropriate)			
Trading title	N B Electrical		
Address	3 Stockbridge meadows Melbourne Meks	Postcode	SK6 6FB
		NICEIC Enrolment No (Essential information)	020316
		Branch number (if applicable)	
<b>E DECLARATION OF CONFORMITY</b>			
<p>In consequence of acceptance of the outcomes declared in Section H of this certificate, I/we* hereby declare that the emergency lighting system installation, or part thereof, described in Section B of this certificate conforms, to the best of my/our* knowledge and belief, to the appropriate recommendations and requirements given in BS 5266-1: 2011, <i>Emergency lighting – Part 1: Code of practice for the emergency lighting of premises</i>, BS EN 1838: 2013 <i>Lighting applications – Emergency lighting</i> and BS EN 50172: 2004, <i>Emergency escape lighting systems</i>, as set out in the outcomes declared in Section H, except for the deviations recorded in Section I.</p> <p>To be signed by either: a) The <b>Responsible Person / Competent Person</b> (England and Wales); b) The <b>Employer or Other Persons</b> (Scotland) or c) The <b>Employer or Nominated Employee</b> (Northern Ireland)</p>			
Signature	D Jones	Date	18-JAN-26
		Name (CAPITALS)	D JONES
<b>F VALIDITY REVIEW AND ESSENTIAL RELATED DOCUMENTS</b>			
<p><b>This certificate is valid only when accompanied by current versions of all the following:</b></p> <p>i) Signed compliance checklist (see Section H)    ii) Photometric design data (see note 1)    iii) Test log book</p> <p>The contractor issuing this certificate MUST sign to verify that i), ii) and iii) above have been supplied with this certificate and that all essential related reference documents have been recorded below.</p> <p><b>Related documents</b> Insert the relevant certificate and design schedule numbers. (Insert N/A if not applicable).</p>			
Electrical Installation Certificate No. (see Note 2)	12040	Design Schedule No(s)	
Minor Electrical Installation Works Certificate No.		Emergency Lighting Periodic Inspection and Test Certificate No. (see Note 3)	
<p><b>Other documents</b></p> <p>In addition to the above, details of other related documents (if any), should be recorded below.</p>			
Signed by the NICEIC Approved Contractor		Reviewed by the Qualified Supervisor	
Signature	D Jones	Date	18-1-26
Name (CAPITALS)	D JONES	Signature	[Signature]
		Date	18/1/26
		Name (CAPITALS)	N BEEDEN
<b>G NEXT INSPECTION</b>			
We, the signatories shown in Sections E and F, RECOMMEND that this installation is further inspected and tested after an interval of not more than [ ]			

- Notes:
- This can be in any of the following formats (in all cases appropriate de-rating factors must be used), and identified to meet worst case requirements:
    - Authenticated spacing data such as ICEL 1001 registered tables; b) calculations as detailed in CIBSE / SLL Guide LG12; c) appropriate electronic format of results.
  - The electrical safety aspects of the emergency lighting installation must also be certified in accordance with BS 7671 – Requirements for Electrical Installations by issuing an 'Electrical Installation Certificate' or, where appropriate, a 'Minor Electrical Installation Works Certificate'.
  - Where this certificate relates to an alteration or addition that necessitated the carrying out of a periodic inspection on the existing emergency lighting installation, the 'Emergency Lighting Periodic Inspection and Testing Certificate' should accompany this certificate.

Please see the 'Notes for Recipient' on the reverse of this page.