

Fire Detection and Fire Alarm System Commissioning Certificate

BS 5839-1: 2017 H.3

Details of the Client

Client: Blenham Realty (Home Counties)
Address: 4 The Limes Springhall Lane Sawbridge W.M
Postcode: CM21 9FB

Details of the Fire Detection and Fire Alarm System

Address: 28 Ferndale Road
Postcode: ME7 2PD
Extent of system: Full Fire Alarm System
The system is:
covered by this certificate:
New:
Modification:

System Examinations and Recommendations

- Tick box(es) or insert N/A (Not Applicable) as appropriate
- All equipment operates correctly
 - Installation work is, as far as can be reasonably ascertained, of an acceptable standard
 - The entire system has been inspected and tested in accordance with the recommendations of Clause 39.2c of BS 5839-1: 2017

The system performs as required by the specification prepared by:

DJ Electrical

a copy of which I/We have been given

- Taking into account the guidance contained in Section 3 of BS 5839-1: 2017, I/We have not identified any obvious potential for an unacceptable rate of false alarms.
- The documentation described in Clause 40 of BS 5839-1: 2017 has been provided to the user

The following work should be completed before/after (delete as appropriate) the system becomes operational

N/A

The following potential causes of false alarms should be considered at the time of the next service visit

N/A

Before the system becomes operational, it should be soak tested in accordance with the recommendations of Clause 35.2.6 of BS 5839-1: 2017 for a period of:

one week weeks

(Enter a period of at least one week, or as defined by the designer whichever is the greatest, or insert N/A if not applicable.)

Certification of Commissioning

I being the competent person responsible (as indicated by my signature below) for the commissioning of the fire detection and fire alarm system, particulars of which are set out above, CERTIFY that the said work for which I have been responsible complies to the best of my/our knowledge and belief with the recommendations of Clause 39 of BS 5839-1: 2017 except for the variations, if any, stated in this certificate:

Variations from the recommendations of Clause 39 of BS 5839-1: 2017 (see Clause 7).

(Continue on additional numbered pages as required)

The extent of liability of the signatory is limited to the system described above

For the COMMISSIONING of the System:

Name (CAPITALS): D. JONES Position: DS
Signature: D Jones Date: 18th JAN 2025

Particulars of the Company Commissioning the System:

Company Name: DJ Electrical
Address: 143 Benny Drive Harlow Essex
Postcode: CM17 9QY

Design Specification and Related Reference Documents

Design Specification	Electrical Installation Certificate No. for fire alarm supply:
Ref No: Date Issued <u>12040</u> Date Issued <u>18.1.25</u>
Design Drawings	Fire Alarm Design
Ref No: Date Issued	Certificate No: Date Issued
'As Fitted'	Fire Alarm Installation
Drawing Nos: Date Issued	Certificate No. Date Issued