PORTABLE APPLIANCE TESTING (PAT)

REPORT/CERTIFICATE

Client: Tungsten Management Group – Unit 115 –accounts by simply –40 Gracechurch St –EC3V 0BT

Property address – 269 Marlborough Rd – Gillingham Kent – ME7 5HS

Tested by : Martin Burns
217 Northumberland Ave
Welling Kent
DA16 2QF

Tested :12-08-2025 Retest date: 11-08-2026
Certificate Number: 076127

Serial Number	Make and model	Location	Voltage (V)	Rating (A)	Fuse rating (A)	Insulation resistance	Earth continuity	Plug, flex and body	OK to use ?
001	**Toaster**	**Kitchen**	**230**	**4**	**13**	>20MΩ	0.06	Yes	Yes
002	Fridge freezer	Kitchen	230	3	13	>20MΩ	0.22	Yes	Yes
003	Nutri bullet	Kitchen	230	3	13	>20MΩ	N/A	Yes	Yes
004	Kettle	Kitchen	230	8	13	>20MΩ	0.33	Yes	Yes
005	Microwave	Kitchen	230	8	13	>20MΩ	0.22	Yes	Yes
006	Coffee maker	Kitchen	230	3	13	>20MΩ	N/A	Yes	Yes
007	Rice cooker	Kitchen	230	4	13	>20MΩ	0.12	Yes	Yes
008	Rice cooker	Kitchen	230	4	13	>20MΩ	0.16	Yes	Yes
009	Vacuum cleaner	Kitchen	230	8	13	>20MΩ	0.23	Yes	Yes
010	Rice cooker	Kitchen	230	4	13	>20MΩ	0.17	Yes	Yes
011	Coffee maker	Kitchen	230	4	13	>20MΩ	N/A	Yes	Yes

PORTABLE APPLIANCE TESTING (PAT) REPORT & CERTIFICATE PAGE 1

Serial Number	Make and model	Location	Voltage (V)	Rating (A)	Fuse rating (A)	Insulation resistance	Earth continuity	Plug, flex and body	OK to use ?

PORTABLE APPLIANCE TESTING (PAT) REPORT & CERTIFICATE PAGE 2

PORTABLE APPLIANCE TESTING (PAT) REPORT & CERTIFICATE PAGE 3