

PORTABLE APPLIANCE TESTING (PAT)

REPORT/CERTIFICATE

Client: Tungsten Management Group Unit 15 Runwell House Farm Chelmsford CM3 8DQ

Property address – 385 Canterbury Street Gillingham Kent ME7 5XS

Tested by : Martin Burns
217 Northumberland Ave
Welling Kent
DA16 2QF

Tested :15-05-2026 Retest date: 14-05-2027
Certificate Number: 076189

<u>Serial Number</u>	<u>Make and model</u>	<u>Location</u>	<u>Voltage (V)</u>	<u>Rating (A)</u>	<u>Fuse rating (A)</u>	<u>Insulation resistance</u>	<u>Earth continuity</u>	<u>Plug, flex and body</u>	<u>OK to use ?</u>
001	Air fryer	Kitchen	230	8	13	>20MΩ	0.22	Yes	Yes
002	Henry Hoover	Mobile	230	6	13	>20MΩ	0.31	Yes	Yes
003	Kettle	Kitchen	230	12	13	>20MΩ	0.29	Yes	Yes
004	Kettle	Kitchen	230	12	13	>20MΩ	0.11	Yes	Yes
005	Fridge freezer	Kitchen	230	2	3	>20MΩ	0.31	Yes	Yes
006	Fridge freezer	Kitchen	230	2	3	>20MΩ	0.41	Yes	Yes
007	Fridge freezer	Kitchen	230	2	3	>20MΩ	0.21	Yes	Yes
008	Fridge	Kitchen	230	2	3	>20MΩ	0.45	Yes	Yes
009	Nutribullet	Kitchen	230	2	13	>20MΩ	Class II	Yes	Yes
010	Blender	Kitchen	230	3	13	>20MΩ	Class II	Yes	Yes
011	Microwave	Kitchen	230	46	13	>20MΩ	0.21	Yes	Yes
012	Toaster	Kitchen	230	5	13	>20MΩ	0.14	Yes	Yes
013	Wash machine	Kitchen	230	12	13	>20MΩ	0.20	Yes	Yes
14	Tumble drier	Kitchen	230	12	13	>20MΩ	0.33	Yes	Yes

