PORTABLE APPLIANCE TESTING (PAT)

REPORT/CERTIFICATE

Client: Tungsten Management Group Lettings Unit 15 Runwell House Farm CM3 8DQ

Property address – 455 Canterbury Street Gillingham ME7 5LJ

Tested by : Martin Burns
217 Northumberland Ave
Welling Kent DA16 2QF

Tested 03-08-2026 Retest date:02-08-2027
Certificate Number: 076229

Serial Number	Make and model	Location	Voltage (V)	Rating (A)	Fuse rating (A)	Insulation resistance	Earth continuity	Plug, flex and body	OK to use ?
001	**Microwave**	**Kitchen**	**230**	**4**	**13**	>20MΩ	0.17	Yes	Yes
002	Toaster	Kitchen	230	3	13	>20MΩ	0.19	Yes	Yes
003	Air fryer	Kitchen	230	12	13	>20MΩ	0.22	Yes	Yes
004	Television	Lounge	230	0.3	13	>20MΩ	Class II	Yes	Yes
005	Washing machine	Kitchen	230	13	13	>20MΩ	0.09	Yes	No Faulty
006	Tumble drier	Kitchen	230	13	13	>20MΩ	0.09	Yes	Yes
007	Kettle	Kitchen	230	13	13	>20MΩ	0.11	Yes	Yes
008									
009									
010									
011									

□

PORTABLE APPLIANCE TESTING (PAT) REPORT & CERTIFICATE PAGE 1

Serial Number	Make and model	Location	Voltage (V)	Rating (A)	Fuse rating (A)	Insulation resistance	Earth continuity	Plug, flex and body	OK to use ?

PORTABLE APPLIANCE TESTING (PAT) REPORT & CERTIFICATE PAGE 2

PORTABLE APPLIANCE TESTING (PAT) REPORT & CERTIFICATE PAGE 3